

Certificate

Certified Passive House Classic

homeGrid[®] Authorised
by:



Dr. Wolfgang Feist
64283 Darmstadt
Germany

Passive House em Amor 2400-XXX Amor, Portugal



Client	Cibele Santos 2400-XXX Amor, Portugal
Architect	Joel Esperança, atelier Contaminar
Building Services	Climacom
Energy Consultant	Esperança Isabel Vieira Lopes de Azevedo

Passive House buildings offer excellent thermal comfort and very good air quality all year round. Due to their high energy efficiency, energy costs as well as greenhouse gas emissions are extremely low.

The design of the above-mentioned building meets the criteria defined by the Passive House Institute for the 'Passive House Classic' standard:

Building quality		This building		Criteria	Alternative criteria
Heating	Heating demand [kWh/(m ² a)]	10	≤	15	-
	Heating load [W/m ²]	13	≤	-	10
Cooling	Frequency of overheating (> 25 °C) [%]	0	≤	20	
	Frequency of excessively high humidity [%]	16	≤	0	
Airtightness					
	Pressurization test result (n ₅₀) [1/h]	0.4	≤	0.0	
Renewable primary energy (PER)					
	PER-demand [kWh/(m ² a)]	32	≤	60	60
	Generation (reference to ground area) [kWh/(m ² a)]	0	≥	-	-

The associated certification booklet contains more characteristic values for this building.

Ílhavo

13/07/2026

Certifier: João Marcelino - Homegrid, Lda